

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

9.2  
5/16/22

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT APRIL 14, 2022 to MAY 12, 2022

1. PERMIT COMPLIANCE FOR MARCH 2022

The treatment plant produced acceptable results for removal of Total Suspended Solids and Biological Oxygen Demand; however, due to rain events and I/I in the collection system, the March average flow (1.1mgd) was over 1.0 mgd that is permitted.

2. MAINTENANCE

- Normal Preventive Maintenance
- Replaced both filter belts on belt filter press
- Replaced 4" isolation valve on pressure relief valve (digester)
- Prep and painting - aeration tank

3. STAFF – Neal and I would like to request a Special Board Meeting in the next week or two to discuss upcoming retirements