

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT AUGUST 12, 2021 to SEPTEMBER 15, 2021

1. PROCESS EFFICIENCY FOR JULY 2021

BOD and TSS concentrations for effluent were normal and within SPDES permit limits. However, removal efficiency for Total Suspended Solids (81%) was below the required 85% in July. Due to the high amount of rainfall (over 10") in July, and resulting high flows due to excessive inflow/infiltration in the Village collection system, influent becomes less concentrated and treatment efficiency decreases. Removal efficiency for Biological Oxygen Demand (89%) was acceptable.

2. MAINTENANCE

- Normal Preventive Maintenance
- Continued painting throughout the plant
- Replaced belt filter press wash water booster pump

3. SPDES SUBMISSIONS

Industrial pretreatment annual reports and mercury minimization plan were submitted to NYSDEC on 8/24/2021.

4. PERSONNEL