

9-5
8/21/23

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JULY 14, 2023 to AUGUST 16, 2023

1. PERMIT COMPLIANCE FOR JUNE 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance/Yardwork
- Painting outer walls of Primary Settling Tank
- Replaced Sludge conveyor rollers
- Ordered replacement parts for Final Clarifier collector rakes
- Grit washer screw conveyor needs replacement (ordered)
- Replaced hour meter on Blower #1
- Primary Settling Tank flight chain and sprockets need replacement (ordered)
- DPW prepping driveway for paving
- Panelview HMI in Primary Building needs replacement (ordered)

3. FACILITY OUTDOOR LIGHTING – update

New exterior lighting is now installed on Control Building providing a much safer facility at night.

4. RESPIRATOR FIT TESTING

As discussed with PESH inspectors, operators will be required to wear full-face, air-filtering respirators during chlorine and sulfur dioxide tank changes. In order to meet the requirements of the OSHA Respiratory Protection Standard, each person will need to pass a pulmonary function test and mask fit test. Masks were ordered and the testing is schedule for 8/17 at Slocum Dickson Medical Group. Documentation will be kept on file at the WWTP for each operator. A mask fit test and training will be required annually hereafter.

We have not received an inspection letter from DOH-PESH yet, but we are continuing to resolve items discussed during their site visit.

5. ANNUAL HARASSMENT AND DISCRIMINATION TRAINING

Employees of the WWTP attended the required annual training on 8/16.