

7-4

12/19/22

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT NOVEMBER 18, 2022 to DECEMBER 14, 2022

1. PERMIT COMPLIANCE FOR OCTOBER 2022

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance
- Duperon FlexRake mechanical bar screen, gearbox needs to be replaced (PO submitted for approval 12/13)

3. PRIMARY TANK CONCRETE REPAIRS AND STAIR REPLACEMENT PROJECT

National Building & Restoration Corp. completed the change order work and the entire project is now finished.

4. NYMIR Insurance Survey

Update on items related to WWTP provided to Board via email 12/13