

8-2  
2/22/22

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT JANUARY 13, 2022 to FEBRUARY 16, 2022

1. PERMIT COMPLIANCE FOR DECEMBER 2021

BOD and TSS concentrations for effluent were within SPDES permit limits. However, removal efficiency for Total Suspended Solids (84%) was below the required 85%. This is a continual problem any time the plant flows are at or near design capacity. High flows caused by I/I in the collection system deliver dilute influent to the plant which inhibits the microbiological process.

2. MAINTENANCE

- Normal Preventive Maintenance and snow removal
- Ordered replacement 4" valve for gas line on roof.
- DPW used the jetter to free a frozen drain line from the belt filter press to primary treatment