

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT JULY 15, 2021 to AUGUST 11, 2021

1. PROCESS EFFICIENCY FOR JUNE 2021

The treatment plant produced acceptable results for removal of Total Suspended Solids (88%) and Biological Oxygen Demand (90%) in accordance with the SPDES permit.

2. MAINTENANCE

- Normal Preventive Maintenance
- Painting throughout the plant including the blower building
- Repaired flame arrester on digester roof
- DPW cut heavy brush along creek

3. CONTRACT REVISIONS