

8-1  
8/15/22

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT JULY 15, 2022 to AUGUST 10, 2022

1. PERMIT COMPLIANCE FOR JUNE 2022

The treatment plant produced acceptable results for Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) in accordance with the SPDES permit.

2. MAINTENANCE

- Normal Preventive Maintenance
- Replaced belt guides and several seals on belt filterpress
- Completed painting Final Clarifier #2
- Need to replace DO probe and cable in aeration tank (PO submitted for USA Bluebook)

3. TRUNK SEWER LINING QUOTES

As discussed during the Special Board Meeting on July 26, 2022, it was discovered during recent televising work that the mainline sewer from Van Buren St. into the treatment plant is damaged and needs to be lined. The lining could be funded by ARPA monies.

4. PRIMARY TANK CONCRETE REPAIRS AND STAIR REPLACEMENT PROJECT (Chet)