

9-3
7/17/23

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JUNE 15, 2023 to JULY 13, 2023

1. PERMIT COMPLIANCE FOR MAY 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance/Yardwork
- Painting outer walls of Primary Settling Tank
- Rebuilt Digester Recirculation/Beltpress Feed Pump
- Snail removal from Aeration Basin
- Driveway milled when Suit-Kote was on Van Buren
- Sludge conveyor rollers to be replaced (expected to arrive this week)
- Ordered replacement parts for Final Clarifier collector rakes
- Grit washer screw conveyor needs replacement (waiting on quote)
- Replaced flight on Primary Settling Tank #1
- Replaced worn flight wear shoes on both Primary Settling Tanks

3. FACILITY OUTDOOR LIGHTING – update

Work on exterior lighting will be scheduled in the next month