

9-1  
7/18/22

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT JUNE 16, 2022 to JULY 14, 2022

1. PERMIT COMPLIANCE FOR MAY 2022

The treatment plant produced acceptable results for Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) for concentration and loading; however, the plant did not meet the required removal efficiency of 85% for Total Suspended Solids (TSS). BOD removal was 93% and TSS was 83%.

2. MAINTENANCE

- Normal Preventive Maintenance
- Painted concrete tanks: final clarifier #1
- Replaced 2 hydraulic cylinders on belt filterpress
- Removed polymer pump for belt filterpress and installed new one
- Adirondack Mechanical - annual backflow preventer test complete

3. SEWER CLEANING AND TELEVISIONING

KPI conducted cleaning and televising of Village sewers as part of the Phase II I/I Investigation. The cleaning and televising was finished on 7/12/22. KPI will be back for another day to finish manhole inspections. Several dozen manholes in the Village have been paved over in the past and DPW has been locating and uncovering them in order to gain access. It is important to have access for maintenance of the sewers.

Significant defects were found in the Baker and Elm St. lines and also the main trunk line that comes into the plant from VanBuren St. We are in the process of evaluating the videos and our options for repair.

4. CONCRETE REPAIRS – PRIMARY TANK (Chet)

5. BARTON AND LOGUIDICE PROPOSAL – PRETREATMENT PROGRAM

As presented during budget time, the pretreatment program hasn't been evaluated for compliance in decades. Barton and Loguidice has provided a proposal to assist me in determining if our program is still in compliance with DEC and EPA regulations. A budgetary line item was approved this year for this work.