

11-1
4/19/21

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT MARCH 10, 2021 to APRIL 13, 2021

1. PROCESS EFFICIENCY FOR FEBRUARY 2021

The treatment plant produced acceptable results for removal of Total Suspended Solids (95%) and Biological Oxygen Demand (96%) in accordance with the SPDES permit.

2. MAINTENANCE

- Normal Preventive Maintenance
- Final clarifier #1 worm gear reducer was delivered; Kaman Industrial is currently working on the drive shaft. Expect to get tank back in service by the end of the month.
- Original (1968-69) backflow preventer replacement-waiting on DOH review/approval.
- Emergency digester cleaning and repair is complete. Digester was put back in service 4/7/21.
- Replaced 5 sludge valves in basement of main building that were part of original plant construction.
- Replaced solar spark vent flare igniter used to ignite waste gas (excess biogas produced by digester). During the digester startup, the waste gas burner will be used to burn off poor quality biogas that can't be used in the boiler.

3. TRAINING

- Attended a 4 half day webinar training presented by USEPA on Industrial Pretreatment March 8 -11.
- Attended annual NYS Discrimination and Harassment webinar training by NYMIR on April 13.

Respectfully Yours,

Amy Mowers
Chief Operator