

9-1
4/18/22

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT MARCH 17, 2022 to APRIL 13, 2022

1. PERMIT COMPLIANCE FOR FEBRUARY 2022

The treatment plant produced acceptable results for removal of Total Suspended Solids and Biological Oxygen Demand.

2. MAINTENANCE

- Normal Preventive Maintenance
- Replaced 2 roller bearing on belt filter press

3. APRIL 7-8, 2022 RAIN EVENT

We measured approximately 2.8" of rainfall for the duration of the event. At around 1am (4/8) flows at the plant exceeded 3.0mgd (design flow = 1.0mgd) and went up to 3.3mgd around 6am. The plant was staffed through the night.

I have included a few photos to show some of the things that happen when that much water is pushed through the plant. We were very thankful the rain stopped when it did.

These flows demonstrate the absolute necessity to continue to work on repairs and rehabilitation in the collection system to remove I/I.

4. CONCRETE REPAIRS – Primary tank and building foundation (Chet)

5. NYSDEC SPDES SUBMISSIONS

Annual flow certification was submitted on 3/23/2022.