

# 7-2  
6/24/21

VILLAGE OF DOLGEVILLE  
WASTEWATER TREATMENT FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT MAY 13, 2021 to JUNE 15, 2021

1. PROCESS EFFICIENCY FOR APRIL 2021

The treatment plant produced acceptable results for removal of Total Suspended Solids (93%) and Biological Oxygen Demand (92%) in accordance with the SPDES permit.

2. MAINTENANCE

- Normal Preventive Maintenance
- Final clarifier #1 worm gear reducer – installed and wired, tank is back in service.
- Original (1968-69) backflow preventer replacement – replaced on 6/15/21