

8-1
6/21/22

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT MAY 13, 2022 to JUNE 15, 2022

1. PERMIT COMPLIANCE FOR APRIL 2022

The treatment plant produced acceptable results for removal of Biological Oxygen Demand; however, due to rain events and excessive inflow and infiltration (I/I) in the collection system, the April average flow (1.2mgd) was over 1.0 mgd that is permitted. The highly diluted influent also caused the plant to not meet the required removal efficiency of 85% for Total Suspended Solids (TSS). Effluent was within permit limits for TSS concentration and loading.

2. MAINTENANCE

- Normal Preventive Maintenance
- Painted concrete tanks: secondary valve pit, chlorine contact tank, aeration tank

3. SEWER CLEANING AND TELEVISIONING

KPI began cleaning and televising areas of the village that are part of the Phase II I/I Investigation. The Village received an Engineering Planning Grant for this work. Notices were posted on-line as well as delivered door to door along streets where work is taking place. As much notice as possible is being given to residents, but depending on conditions found during work, the scheduled streets are changing daily.