

9-3
11/20/23

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT OCTOBER 12, 2023 to NOVEMBER 15, 2023

1. PERMIT COMPLIANCE FOR SEPTEMBER 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance/Yardwork
- Grit washer screw conveyor needs replacement (delivered 11/13, install planned for after Thanksgiving)
- Rehabilitation of all telescopic valves (Complete)
- Primary Settling Tank flight chain and sprockets replacement (Complete)
- Chlorination/Dechlorination system shut down for winter
- Building boxes to protect primary drive chain and gas bubble air supply hosed during the winter months from freezing and snow damage.

3. FLOW METER – (Completed Nov. 1) Effluent flow meter for the plant was damaged during lightning storm on September 9. Aqualogics has repaired the meter and will reinstall the meter on October 30.

4. PESH INSPECTION – (Update) WWTP was inspected by DOL on March 21 and received a notice of violation on September 29. Due dates for compliance vary from October 12 to December 11. PESH will return for follow-up in December. The items due in October and November are complete.

Barton & Loguidice is working on a fall protection solution for accessing the upper portions of the waste gas burner during maintenance activities. I will keep the Board informed as we get closer to the December deadline and the planned corrective action. We may need to apply for an extension.

5. TRAINING – Our Operator Trainee is attending a 2-week course at SUNY Morrisville to complete the Basic Operations course, the first of 3 courses he must successfully pass prior to applying to take his NYSDEC Grade 2A certification exam.