

7-1

10/16/23

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT SEPTEMBER 21, 2023 to OCTOBER 11, 2023

1. PERMIT COMPLIANCE FOR AUGUST 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance/Yardwork
- Grit washer screw conveyor needs replacement (being manufactured)
- Rehabilitation of all telescopic valves (3 of 5 complete)
- Primary Settling Tank flight chain and sprockets need replacement (ordered)

3. FLOW METER – (Update) Effluent flow meter for the plant was damaged during lightning storm on September 9. Aqualogics has repaired the meter and will reinstall the meter on October 30. In the meantime, Aqualogics provided a meter so that we can maintain SPDES compliance.

4. PESH INSPECTION – (Update) WWTP was inspected by DOL on March 21 and received a notice of violation on September 29. Due dates for compliance vary from October 12 to December 11. PESH will return for follow-up in December. The items due in October are complete, other items are in process. The only item we may need to apply for a time extension on is the fall protection for the area of the roof near the waste gas burner.