

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT AUGUST 17, 2023 to SEPTEMBER 20, 2023

1. PERMIT COMPLIANCE FOR JULY 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance/Yardwork
- Grit washer screw conveyor needs replacement (being manufactured)
- Replaced turnbuckles on Final Clarifier rake arms
- Repair Final Clarifier #1 skimmer basket
- Rehabilitation of all telescopic valves (2 of 5 complete)
- Primary Settling Tank flight chain and sprockets need replacement (ordered)
- Replaced Panelview HMI in Primary Building

3. PAVING – Suit Kote paved upper parking lot 8/23/23

4. FLOW METER – Effluent flow meter for the plant was damaged during lightning storm on 9/9/23. Aqualogics is working on replacement that will provide same functionality as the old meter. In the meantime, Aqualogics provided a meter so that we can maintain SPDES compliance.

4. RESPIRATOR FIT TESTING – update – COMPLETED

4. ASSISTING WATER DEPT.

WWTP staff has been assisting with covering shifts at the reservoir during the repair project and as needed during watershed logging situation.