

9-1
2/13/24

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JANUARY 12, 2024 to FEBRUARY 7, 2024

1. PERMIT COMPLIANCE FOR DECEMBER 2023

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance
- Prepping belt filter press room floor for refinishing
- Backup high level alarm float in wet well failed; replacement will be installed by J&A Electric
- 2 Gas unit heaters need replacing, getting quote
- Changing out remaining light fixtures in facility from fluorescent to LED bulbs

3. PESH INSPECTION – (Update)

In 2023, the WWTP had 2 NYSDOL PESH inspections (March and June). As a result, 2 separate notices of violation were issued, one in September and one on 1/17/24. The only remaining item from the September notice is fall protection on the roof at the waste gas burner, deadline was extended to June 1. We are waiting for a proposed design from B&L.

The second notice has citations related to confined space and respiratory protection. A representative from PESH's consultation branch was at the plant on 1/24/24 for assistance bringing the confined space program into compliance. The items related to respiratory protection are resolved. The deadline for all items in the second notice is March 11. There are also several other items that were discussed during the consultation visit that will need to be fixed pertaining to fall protection and tank entry for maintenance. Although they weren't specifically cited in the violation letter, they will be addressed in the next few months.