

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

10 - 1
10/17/22

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT SEPTEMBER 15, 2022 to OCTOBER 12, 2022

1. PERMIT COMPLIANCE FOR AUGUST 2022

The treatment plant produced acceptable results for Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) in accordance with the SPDES permit.

2. MAINTENANCE

- Normal Preventive Maintenance
- Installed new dissolved oxygen probe in aeration tank

3. PRIMARY TANK CONCRETE REPAIRS AND STAIR REPLACEMENT PROJECT

National Building & Restoration Corp. was awarded the project and completed demolition of the stairs and upper primary tank wall this week. Work to rebuild stairs and tank wall will be performed over the next month.

4. MAIN ST. SEWER PROJECT DESIGN

Survey and design progressing. Village DPW locating and raising covers on many buried manholes throughout the project corridor.