

Feb-22	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
1			0.00	0.034	0.080	15	0.92	0.064	1.169	95	7	
2			0.00	0.034	0.081	19	0.98	0.062	1.082	88	7	
3			0.40	0.034	0.118	17	0.92	0.052	1.044	82	6	
4			10"s	0.035	0.182	14	0.78	0.069	1.018	75	7	
Sat. 5			2"s	0.037	0.127	6			1.018	68	7	
Sun. 6			0.00	0.037	0.111	2			1.081	61	7	
7			0.00	0.037	0.095	3	1.04	0.041	1.128	54	7	0.93
8			0.00	0.037	0.094	19	0.90	0.066	1.057	47	7	
9			0.5"s	0.037	0.094	20	0.81	0.064	0.961	40	7	
10			0.00	0.036	0.095	21	0.78	0.049	0.926	33	7	
11			0.00	0.037	0.098	21	0.63	0.068	0.912	26	7	
Sat. 12			0.20	0.037	0.104	13			0.919	19	7	
Sun. 13			0.00	0.037	0.112	3			0.997	12	7	
14			0.00	0.037	0.102	5	0.97	0.041	1.063	8-148	6	
15			0.00	0.040	0.091	23	0.79	0.061	1.012	4-146	6	
16			0.00	0.083	0.091	22	0.69		0.942	140	6	
17												
18												
Sat. 19												
Sun. 20												
21												
22												
23												
24												
25												
Sat. 26												
Sun. 27												
28												
Total	-	0		0.629	1.675	223	10.210	0.637	16.329	840	108	0.93
Average	#DIV/0!	#DIV/0!		0.039	0.105	14	0.85	0.058	1.021	60	6.8	0.93

8-3
2/22/22