

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for March 21<sup>st</sup>, 2022

---

**Water Plant**

- 1) Spring filter cleaning will begin next week as weather permits.
  - 2) DOH completed semi-annual inspection, waiting for report.
  - 3) 1<sup>st</sup> quarter PFOAs and Haloacetic acids (Haa5) and Trihalomethanes (THMs) samples were collected 2/9/2022. Results PFOAs no detection, Haa5 24.2 ug/l average is 49.53 (limit 60) THMs 33 ug/l average is 57.85 (limit is 80)
  - 4) Changes were signed to the Lead & Copper rule, service line inventory needs to be completed by October of 2024.
  - 5) Leak detection survey is scheduled for this spring.
  - 6) DPW fixed 2 water main line breaks 1<sup>st</sup> on Stewart St. 4 inch main broke and the same on Timmerman St.
  - 7) Attended Lab refresher training on March 1<sup>st</sup>, as required for Operator recertification.
  - 8) Any questions or concerns feel free to call, text or Email.
- 

**Attachments**

- 1) February, water plant flow report.
- 2) Land map.

Respectfully, Neal A. Winkler, Water Plant Operator.

