

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for March 20th, 2023

Water Plant

- 1) Filter cleaning as needed.
 - 2) Hexachlorocyclopentadiene, still waiting for word from DOH on what course of action they will require for samples collected in 2022. Using a different lab samples collected on 2/21/23, there was **NO** detections.
 - 3) DOH completed semi-annual inspection, still waiting for report.
 - 4) 1st Quarter Haloacetic acids and Trihalomethanes (DBP) were collected on 2/15/23 results were well below the limits again.
 - 5) On 2/7/23 we located on the service line going to residence at 209 Hopson Rd. upon speaking with the home owner she knew there was a leak, I informed her she needed to get a contractor there to fix. As of this date there has been no action, I would like the board to send a letter giving 30 days for repairs or water will be turned off.
 - 6) Working with Chet to plan reservoir wall repairs, waiting on permits.
 - 7) Any questions or concerns feel free to call, text or Email.
-

Attachments

- 1) February, water plant flow report.

Respectfully, Neal A. Winkler, Water Plant Operator.

