

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for October 16th, 2023

---

**Water Plant**

- 1) Filter cleaning as needed. Cleaned 3 filters after the logging issue, filters are holding good for now.
- 2) Work on the Reservoir spill way is complete, working with the DPW to get things cleaned up before winter.
- 3) Third Quarter DBPs sample results were off the charts, THMs at 150ug/l quarterly at 68.43, MCL is 80. Haa5 was 123ug/l quarterly average at 58.78 MCL is 60. Next sampling scheduled for second week of November will probably put us over the limits.
- 4) Training, webinar to apply for free technical assistance to protect drinking water Oct. 25<sup>th</sup> application is due Nov. 14<sup>th</sup>. Class room training Nov. 8<sup>th</sup> in Johnstown for Hydrant and Valve maintenance with Dave.
- 5) Working on a list of commercial customers that require backflow prevention as requested by DOH.
- 6) Scott Hongo, inspections are moving along.
- 7) As of this report (10/12/23) I have no updates from DEC on the logging issue. 1.4inches of rain on 10/7 and 0.8 inches on 10/8 elevated raw water turbidity to 0.762, far lower than 9.628 in August.
- 8) Any questions or concerns feel free to call, text or Email.

---

**Attachments**

- 1) September, water plant flow report.
- 2) Disinfection By Products spread sheet
- 3) Couple photos of the spill way before and after.

Respectfully, Neal A. Winkler, Water Plant Operator.