

To: Village Board of Trustees  
From: Scott Hongo, Superintendent of Public Works  
Date: 10/16/2017  
Re: October 2017 Monthly Report

---

**Current Work:**

- Repaired water leak at 36 W State St.
- Camera 34 Ransom St
  - Existing trap in lateral impede view to main, Trap removed allowing camera in entirety, Homeowner issue
- Leaf sucker repairs made and put into service
- Repaired Hydrant #74 on the corner of Ransom St/E. Spofford Ave.
- Hydrant #57 on VanBuren St scheduled for replacement
  - Awaiting rental vacuum excavator equipment
  - Finally, being delivered 10/13/17 allegedly
    - This is needed due to the gas main being close to the hydrant and the subcontracted locator for National Grid is not confident in the location due to the proximity of water lines to gas lines
- Prepping snow removal equipment
- Siding at pavilion replaced
- Found more missing manholes
- Checked and flushed dead ends on sewer runs as needed
- As always weekly and monthly checks have been made of the sewer system "trouble" areas
- Loader replacement should still be considered

Respectfully Submitted

Scott Hongo  
Superintendent of Public Works