

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: May, monthly report

Submitted for June 18th, 2018

Water Plant

- 1) 2nd quarter Disinfection By Products samples were collected May 9th, Haloacetic acids results were 57 bring our 4 quarter average to 47.2 with the limit being 60.
- 2) Sand for resending filters, demo.
- 3) Received second quote for 29A water line work, no others returned quotes. Contacted a total of 6.
- 4) Plans are under way for cleaning the reservoir on July 2nd, weather permitting. If weather conditions stay dry as it has been for May we may have to reschedule at a later date.
- 5) Filter cleaning is ongoing as weather permits.

Attachments (available at office)

- 1) May, water plant flow report.
- 2) 29A project quotes.

Respectfully, Neal A. Winkler, Water Plant Operator.

Dolgeville Monthly Report

	A	B	C	D	E	F	G	H	I	J	K	L	M
36	Average	635,360	600,471		0.061	0.167	15	0.66	0.073	1.041	75	10.0	0.56