

Dolgeville Monthly Report

	A	B	C	D	E	F	G	H	I	J	K	L	M
	Date	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
1	1	597,859	504,387	0.10	0.072	0.132	39.0	0.74	0.071	1.259	13	12	
2	2	586,756	458,957	0.80	0.045	0.154	31.0	0.88	0.054	1.182	141	10	
3	Sat. 3	484,890	330,750	0.60	0.048	0.304	19.0	0.55		1.186	132	9	
4	Sun. 4	423,446	352,723	0.50	0.058	0.236	11.0	0.51		1.098	122	10	
5	5	457,261	552,510	0.00	0.096	0.158	14.0	0.84	0.058	1.166	113	9	0.45
6	6	531,004	523,869	0.90	0.081	0.218	29.0	0.76	0.071	1.216	103	10	
7	7	526,274	545,028	0.90	0.098	0.408	36.0	0.44	0.084	1.054	93	10	
8	8	562,637	541,466	0.00	0.119	0.189	44.0	0.29	0.116	0.951	83	10	
9	9	583,368	555,397	0.00	0.094	0.146	46.0	0.51	0.096	1.098	71	12	
10	Sat. 10	551,316	344,257	0.80	0.079	0.308	50.0	0.59		1.356	57	14	
11	Sun. 11	510,447	356,233	1"s	0.093	0.177	28.0	0.65		1.047	50	7	
12	12	496,497	556,045	0.00	0.099	0.126	27.0	0.72	0.101	0.972	41	9	
13	13	550,532	525,819	2"s	0.082	0.115	33.0	0.31	0.104	0.976	32	9	
14	14	549,209	555,813	2"s	0.073	0.114	34.0	0.44	0.093	0.989	25/148	9	
15	15	551,302	586,037	0.00	0.067	0.102	44.0	0.47	0.095	1.091	138	10	
16	16	598,208	496,251	6"s	0.061	0.095	45.0	0.61	0.085	1.142	128	10	
17	Sat. 17	611,709	357,573	0.20	0.055	0.098	36.0	0.62		1.065	119	9	
18	Sun. 18	507,504	355,830	0.00	0.054	0.096	11.0	0.57		1.161	109	10	
19	19	520,861	546,269	2"s	0.053	0.092	2.0	1.18	0.088	1.308	99	10	
20	20	611,116	610,382	0.00	0.053	0.091	10.0	0.87	0.106	1.048	93	6	
21	21	605,307	455,693	.25"s	0.052	0.091	12.0	0.75	0.105	0.972	86	7	0.37
22	22	508,136	376,935	2"s	0.050	0.091	0.0	0.61	0.084	0.994	78	8	
23	23	474,824	369,127	0.00	0.048	0.082	0.0	0.81	0.096	1.115	71	7	
24	Sat. 24	460,586	373,416	0.00	0.046	0.080	0.0	0.68		1.139	65	6	
25	Sun. 25	465,586	400,603	0.90	0.046	0.139	0.0	0.59		1.095	60	6	
26	26	521,794	609,668	0.01	0.055	0.161	6.0	0.92	0.064	1.049	55	5	
27	27	596,190	593,278	0.80	0.068	0.203	17.0	0.46	0.091	0.971	47	8	
28	28	638,303	613,283	6"s	0.075	0.144	23.0	0.62	0.072	0.887	39	8	0.61
29	29	645,479	592,090	1"s	0.069	0.115	23.0	0.52	0.099	1.032	29	10	
30	30	631,780	573,029	0.00	0.062	0.105	20.0	0.61	0.108	1.193	18	11	
31													
32													
33													
34	Total	16,360,181	14,612,718	6.51	2.051	4.570	690.00	19.120	1.941	32.812	2,285	271	1.43
35				21.25"s									
36	Average	545,339	487,091		0.068	0.152	23	0.64	0.088	1.094	79	9.0	0.48

7-2
12/17/18