

Dolgeville Monthly Report

A	B	C	D	E	F	G	H	I	J	K	L	M
Date	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
1	564,000	360,659	.25"s	0.058	0.096	14.0	0.59		1.158	143	9	
2	Sat. 1 472,962	373,805	1.25"r	0.054	0.254	0.0	0.55		1.214	134	9	
3	Sun. 2 512,837	583,877	.5"r	0.074	0.423	4.0	0.96	0.070	1.136	125	9	0.79
4	578,526	552,398	.2"r	0.101	0.219	18.0	0.66	0.076	1.294	111	14	
5	590,936	548,738	0.00	0.084	0.141	19.0	0.93	0.089	1.266	97	14	
6	589,687	577,762	0.00	0.078	0.233	17.0	0.88	0.091	1.291	85	12	
7	613,878	571,893	.2"s	0.066	0.186	23.0	0.76	0.101	1.245	72	13	
8	7 550,922	369,858	0.00	0.061	0.163	16.0	0.62		1.174	62	10	
9	Sat. 8 464,041	385,824	2"s	0.057	0.155	16.0	0.58		1.213	51	11	
10	Sun. 9 506,571	600,779	0.00	0.055	0.154	5.0	1.22	0.063	1.476	42	9	
11	10 611,619	592,679	0.00	0.053	0.159	18.0	1.08	0.079	1.291	33	9	
12	11 630,126	601,414	.5"s	0.051	0.157	16.0	0.81	0.101	1.143	22	11	
13	12 642,546	598,280	0.00	0.051	0.145	18.0	0.63	0.056	1.075	11	11	
14	13 637,343	562,268	2"s	0.051	0.145	16.0	0.61	0.088	1.032	7	4	
15	14 554,547	376,189	0.00	0.050	0.144	8.0	0.57		1.064	0	7	
16	Sat. 15 494,607	385,678	0.00	0.050	0.146	0.0	0.55		1.171	148	8	0.44
17	Sun. 16 547,659	594,832	.2"r	0.050	0.154	4.0	1.05	0.063	1.137	141	7	
18	17 604,170	561,574	2"s	0.050	0.165	10.0	0.42	0.082	1.021	134	7	
19	18 582,817	514,397	0.00	0.049	0.147	10.0	0.83	0.059	0.967	127	7	
20	19 570,252	567,034	0.00	0.049	0.143	7.0	0.36	0.091	1.026	120	7	
21	20 586,675	512,816	.25"r	0.048	0.243	11.0	0.66	0.07	1.052	112	7	
22	21 517,944	413,775	1"s	0.057	0.925	4.0	0.57		1.100	104	9	
23	Sat. 22 469,986	389,088	2"s	0.073	0.382	0.0	0.61		1.094	97	7	
24	Sun. 23 469,057	397,360	1"s	0.072	0.237	0.0	0.57		1.056	89	7	
25	24 465,602	375,768	2"s	0.063	0.188	0.0	0.60		1.032	81	8	0.38
26	25 527,415	607,657	0.00	0.058	0.164	4.0	0.84	0.064	1.068	73	8	
27	26 598,077	588,764	.5"s	0.054	0.157	12.0	0.38	0.081	0.992	64	9	
28	27 602,808	508,307	.1"r	0.052	0.191	14.0	0.58	0.066	1.022	56	8	
29	28 508,154	378,711	.4"r	0.057	0.481	5.0	0.62		1.008	48	8	
30	Sat. 29 457,336	380,770	0.00	0.066	0.257	0.0	0.56		1.058	40	8	
31	Sun. 30 455,464	381,716	.5"s	0.063	0.188	0.0	0.59		1.079	33	7	
32	31											
33	Total	16,978,564	15,214,670	2.9"r	1.855	289.00	21.240	1.390	34.955	2,462	274	1.61
34	Average	547,696	490,796	15.75" S	0.060	0.224	9	0.69	1.128	79	8.8	0.54

4/2/18