

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Jan-19												
1	456,520	383,633	1.1r	0.059	0.659	0.0	0.67		1.089	25	8	
2	525,020	641,049	0.00	0.064	0.333	5.0	0.96	0.069	1.121	17	8	0.39
3	613,375	585,282	3"s	0.065	0.218	17.0	0.44	0.071	0.913	17	8	
4	624,918	627,129	0.00	0.059	0.182	18.0	0.41	0.070	0.852	147	9	
Sat. 5	574,111	363,818	0.00	0.055	0.163	15.0	0.58		1.131	135	12	
Sun. 6	469,681	373,627	0.00	0.053	0.155	0.0	0.66		1.262	125	10	
7	533,343	634,451	.5"s	0.051	0.149	5.0	1.06	0.061	1.189	117	8	0.35
8	610,236	613,097	1"s	0.049	0.153	17.0	0.51	0.068	1.021	109	8	
9	652,093	651,719	3"s	0.048	0.181	23.0	0.78	0.074	1.016	100	9	
10	652,058	616,232	1"s	0.048	0.169	24.0	0.37	0.081	1.001	91	9	
11	654,932	624,423	1"s	0.049	0.153	25.0	0.65	0.077	1.056	82	9	
Sat. 12	589,286	405,893	0.00	0.047	0.144	19.0	0.61		1.121	72	10	
Sun. 13	508,588	416,790	0.00	0.047	0.137	5.0	0.64		1.127	64	8	
14	541,928	617,486	0.00	0.047	0.134	2.0	1.02	0.059	1.165	56	8	
15	613,989	613,490	0.00	0.046	0.133	13.0	0.98	0.061	1.108	48	8	
16	635,642	631,865	0.00	0.046	0.140	14.0	1.05	0.066	1.124	39	9	
17	656,583	639,061	0.00	0.046	0.137	18.0	1.02	0.056	1.129	30	9	0.61
18	676,695	688,166	0.00	0.046	0.134	21.0	0.60	0.080	1.056	22	8	
Sat. 19	619,860	412,596	.5"s	0.045	0.136	19.0	0.59		1.015	13	9	
Sun. 20	499,363	416,588	18"s	0.046	0.167	0.0	0.62		1.142	4	9	
21	536,217	621,001	0.00	0.046	0.146	3.0	1.11	0.064	1.209	-4	8	
22	607,070	602,476	0.00	0.045	0.136	13.0	1.03	0.081	1.195	143	8	
23	637,021	656,591	0.00	0.045	0.134	16.0	1.01	0.059	1.179	136	7	
24	646,263	582,812	1.75r	0.045	0.486	19.0	0.51	0.063	1.131	129	7	
25	599,520	542,026	.5r	0.065	0.764	15.0	0.63	0.071	1.117	120	9	
Sat. 26	533,557	421,551	2"s	0.087	0.402	9.0	0.56		0.996	111	9	
Sun. 27	474,131	434,928	0.00	0.076	0.269	1.0	0.59		0.989	102	9	
28	529,940	661,472	3"s	0.065	0.205	4.0	0.68	0.061	0.905	96	6	0.54
29	684,167	727,549	0.00	0.059	0.177	24.0	0.64	0.077	0.963	86	10	
30	728,082	699,040	9"s	0.054	0.172	29.0	0.60	0.079	1.048	76	10	
31	707,485	643,491	1"s	0.052	0.156	25.0	0.42	0.072	1.113			
Total	18,391,674	17,549,332	3.35" R 43" S	1.655	6.824	418.00	22.000	1.520	33.483	2,308	259	1.89
Average	593,280	566,107		0.053	0.220	13	0.71	0.069	1.080	77	8.6	0.47

2/18/15