

The Village of
Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

Date: 02/17/2022

Re: January 2022 Monthly Report

Work: Current

- Weekly Checks of Sewers
- Shoveling Village Walkways,
Plowing and Salting
- Daily 811 Requests
- Checking Storm drains

Water/Sewer

- Jetted Faville Ave.
- Ran Camera on Faville/Helmer Ave (Jim McKinney). Removed an obstruction Faville/Helmer. Problem Resolved.
- Jetted Line at Fire Station due to a slow Main. Problem Resolved.
- Flushed Sewer at Cramer Lane.
- Met with Manheim to Schedule Sewer Jetting for frozen Sewer. Jetted and Problem resolved.
- Bever St Storm Drain Froze due to shallow drain.
- 3 West State St located Curb Stop, worked with Welder to thaw Sewer line, no resolve. Back fed residents from a neighboring house until a better option for thawing can be located. Problem resolved as of today.
- Water Leak on East Timmerman. Located Valve and Tested. Problem is resolved.
- 8 Slawson Cleared out Curb Stop for Homeowner to replace inside Valve.

- Sewer Complaint 5 South Second St. Bagged, used camera and checked Main. Roots in line. Advised Homeowner to get Plumber to cut lines.
- Sewer Complaint Elm St, checked Main for obstructions and none found.
- Sewer Jetted on Cavalli St. Heavily plugged, called Hereunder and problem is resolved.
- Missing Manhole on Fink St/Helmer- Trying to locate.

Flooding

- Checked and Monitored Creeks in the Village and North of the Village.
- Road Closures, Reflectors and tape, Water Shut offs and Extra Salting on Ice from Flooding.
- Called for Mutual Aid from Oppenheim, they brought a loader, excavator, 2 guys for 6 Hours. PD had 1 car for

Traffic/Crowd control. State DOT brought 1 Excavator, 2 Light Plant's, approximately 10 people, 5 to 8 Pickup's, 1 Truck and Low Boy trailer.

- 5 Residents Displaced on Vanburen as well as 2 dogs.
- Removed Ice from Bever Brook outlet. Evacuated Van Buren and Dolge Ave Twice. Removed Ice flow from residents and salted.

Streets

- Still Cold Patching
- Fixed stop sign on Howard St.
- Cleaned Ditch line on Second St
- Met with Chet about Summer Projects.
- Opened up Cemetery per Request
- Shoulder Work done on Millers Grove Road.

Garage

- Snowman Transmission is in along with fluids changed. No issues.
- 09 Freightliner's Steer Tire Changed due to laceration of side wall.
- Radio is installed in 3500.
- 550 went back for frame cracking recall and Transmission recall and electronics recall.
- 12 Freightliner- New Sensor Purchased, attempted install in house and sensor broke off so it was sent to Winkler repair. Truck still shuts down randomly.

To Do:

- Cold Patching
- Update Water Books
- Continue to train new employees
- Keep trucks serviced and cleaned.
- Start Sewer Line Cleaning
- Start prepping Summer Equipment