

8.5
2/22/22

The Village of
Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

Date: 02/17/2022

Re: January 2022 Monthly Report

Work: Current

- Weekly Green Waste Collection
Done until Spring
- Weekly Checks of Sewers
- Shoveling Village Walkways,
Plowing and Salting
- Daily 811 Requests
- Checking Storm drains

Water/Sewer

- Checked Kinney's and Timmerman Street Sewers. Flushed Sewer at Kinney's. Repaired fill at Water leak site
- Sewer plug on Horn St. Jetted and Cleared.
- Used Camera on WWTP drain Line. Retrieved stuck Jetterline and rebuilt part of drain line. Unplugged same and tested.
- Bergeron's plugged/Frozen Sewer. Checked Sewer and met with Bergeron's. Worked on and believe problem corrected.
- Jetted Main on Schuyler St that was a plugged Main. Now cleared.
- Ordered mini jets for sewer lines
- Sewer plug/frozen sewer Spofford Ave. Checked Main and we bagged the lateral. Camera and used mini jets to break up ice and free lateral

Streets

- Snow removal throughout Village
- Cleaning of Kinney's lot, opening of cemetery, Sidewalks, and cleaning around fire hydrants.
- Cold Patching State St and Helmer Ave.
- Exposed Manhole Cover Wolf @ Helmer Ave-Fixed
- Looked into Pothole complaint on State St- "Blown Tire"-took pictures.
- Water Leak on Stewart St- Repaired

Garage

- 3500 Still needs radio installed. Serviced this Month in house greased body and chassis
- "12" Freightliner was sent to Dennis to investigate Check light engine. No findings.
- "09" Freightliner- rear lights fixed.
- Bobcat- Greased and Cleaned air and cabin filters. Snowblower hooked up.

- Excavator- Changed fluids and filter in house.
- “F550”- Changed oil in house. Took to Brown’s for recall work. Frame cracking, bad bearing in transmission and electronics needed re-flashing. Should be done in a couple days.
- “Snowman”- Ran out of fuel, refilled, and reprimed motor. Pulled transmission and replaced with unit at Garage.
- Gas Powered Heater in Breakroom still needs replacement.
- Tarped roof is leaking. Need to discuss insurance claim
- Greg is getting his road time in.
- Temporary light put in bathroom along with a new heater.
- Made arrangements with Rawlings for more sawdust.
- Changed locks on DPW Garage per Boards request.
- Gas Handle damaged-now repaired

Parks:

- Cleaned up after all trees cut down by Rick Barnes.

To Do:

- Cold Patching
- Update Water Books
- Continue to train new employees
- Keep trucks serviced and cleaned.