

8-5
1/17/23

The Village of
Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

Date: 01/11/23

Re: January 2023 Monthly Report

Work

Current

- **Weekly Checks of Sewers**
- **Daily 811 Requests**
- **Checking Storm drains**
- **Continue cleaning Sewer Lines**
- **Weekly Metal Pick up**
- **Park Bench restoration**
- **Water Leaks throughout Village**

Water/Sewer

- **Plowing WWTP**
- **Replaced Water Cap (Howard at Faville)**
- **Checking and clearing storm drainers before Christmas Storm.**
- **Fixed Water Service at the top of Faville Ave.**
- **Tarped siding at Water Treatment Plant**
- **Checked Lamberson for Sewer back up (Unfounded).**
- **Water shut offs and turn on.**
- **Investigate Water Complaint 24 West State- Found leak, called in 811 Request. Digging will be 1/15/23 Weather Permitting.**
- **Aided Fire Department with hoses and Sewer bag for a Hazmat Situation.**

Streets

- **Christmas Pole Decorations taken down**
- **Plowing Streets and Clean up**
- **Finished working on McKinley storm drain**
- **Cleaning sidewalks after storms and salting of sidewalks and parks.**
- **Called in Broken Christmas Lights**
- **Opened Cemetery**
- **Checked and Opened Storm drains**
- **Ordered Street signs for Satisfy Insurance Company**
- **811 Request for S. Main St- Beaver Brook Culvert**
- **Tree pick up until the end of January**
- **Cold Patching is ongoing**
- **Checking water level on Ranson before and after storms.**

Garage

- **"09" Freightliner- New Salt chain, discovered several holes in the salt tray (Not patchable, Metal is too thin). Truck was cleaned and serviced along with Brakes adjusted. Will need all 4 Brakes replaced in the Spring.**
- **550 – Cleaned and Serviced, cutting edges installed and cleaned, fluid film undercoating (Rust Control)**
- **F350- We should talk about the selling.**
- **3500- Oil change done, cleaned and fluid film undercoating.**
- **12 Freightliner- Cleaned, Greased and had brakes adjusted. 1 slack adjuster is not functioning well- Will be in fixed in Spring.**
- **Leaf Picker- in storage**
- **Sweeper- same issues**
- **Sewer Jet-**
- **Skid Steer-**
- **Monthly Fuel Tank Check and inspections**
- **Salt Deliveries then mixed with sand**
- **Snowman- New set of cutting edges installed. We need to address the charging system issues.**
- **Derek has been receiving Machine Practice.**
- **Loader- 1K hour Service done and cleaned**
- **Back Hoe- Cleaned and Greased**
- **Fuel tank Gauges are on order through Buell Fuels per DEC after Inspection.**

- Garage has 8 new 4-foot LED lights installed to improve lighting per Board Request.
- Researching repairs for the alarm system on the Garage. 1 response- They will be in the 18th to repair the faults in our existing alarm system (\$1k). To get alarm System functioning and monitored it will be an additional \$1550 per my previous email.
- Fixed water Leak above Bathroom at Garage.

Parks

- Park Bench Rehab is still in the works- Installed 1 and pulled another to work on.
- Greenway Trail- Will be ordering Concrete Blocks in the Spring Per Insurance.
- Plowe Park- Repaired Electric Eye and Replaced Bulb on flags. Took down Christmas Decorations at Gazebo.
- Center Park- Working on Force Account. Pavilion was removed, Wading Pool removed, Concrete block pulled and hauled away. Awaiting word on the pool footer if it needs to be removed. Fence Line Removed along with Trees and Green Waste Hauled away.

To Do:

- **Update Water Books**
- **Continue to train new employees**
- **Keep trucks serviced and cleaned.**
- **Cleaning and Organizing Garage**
- **"09" Freightliner- Rust Control.**
- **Removal of sediment at Reservoir to create room for next year.**
- **Burt St- Remove Vegetation**