

10-4
11/21/22

The Village of Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

Date: 11/16/2022

Re: November 2022 Monthly Report

Work:

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up-slowng down
- Park Bench restoration
- Water Leaks throughout Village

Water/Sewer

- Inspection for Rate reduction-10 Faville Ave.
- Changed meters at Water Treatment and ran wire.
- Investigated ponding water on Dolge Ave Ext- Homeowner was pumping basement out.
- Turned water on at Spofford Square-Per Homeowner request.
- Water shut off list completed.
- Water leak-South Helmer= We fixed original leak with wrap clamp. Discovered the adjacent bell was leaking at the lead. Installed a bell joint clamp to seal. Problem resolved.
- Reinstated driveway on E. Timmerman from this past spring's water leak.

Streets

- Green waste done as of Monday but will still trucks be dropping trucks off to residents as requested.
- Met with Parkside “Cut off pole in ground”- They had questions about signage due to hitting with mower. Will be put on list for removal.
- Cold Patching throughout Village.
- Leaf pick up started
- Started Mutchler Hill Project- Ditching and landscaping on hill to prevent Ice build up on road during winter.
- Repaired storm Drain #1 and repaired storm line due to crushing on Cline St.
- Worked traffic control on Main St for Engineers.
- Pulled flowers on Main St.
- Gas Leak- Helmer Ave
- Flags taken down
- Road side markers put up on Cavalli St.
- Plowing season has officially started.
- Standby at State St Bridge for Traffic duty Per DOT.
- Funeral Detail

- Decorations for Christmas on Main St have arrived and have been tested for function and will be put up soon.

Garage

- 09 Freightliner- Power issues fixed; salter is repaired. It is currently back. Repaired Headlight 11/16/2022. Head plow and wing are on. It has a blower motor issue. Reverse lights are non-functional, will be repaired soon. Municipal Radio cuts out intermittently- We will be investigating. Cab Airbag is leaking/deflated. Will need to source and replace.
- 550 – Installed salter and tested it.
- F350- no new issues
- 3500- New Mirror installed
- 12 Freightliner- New Hydraulic line 11/16/22. Head plow and wing are on and salter is in it.
- Leaf Picker- Repaired radiator, repaired Governor and changed a fuel line filter.
- Sweeper- same issues
- Sewer Jet line has been replaced
- Skid Steer- nothing new to report

- Garage Lift Rams- Reinstalled and functioning.
- Monthly Fuel Tank Check and inspections
- Installed locks on tanks.
- Heater in Breakroom- repaired- Pilot light keeps extinguishing
- Snowman- Repaired starter
- Propane tanks filled
- Derek has been receiving Machine Practice.
- Ordered 70 tons of salt. Stirred up salt and added a 1-ton load of sand and mixed.
- Picked up fluids and filters for V-Plows and serviced them.
- DOT shared service Agreement complete.
- Cutting edges- Need to order
- Back Hoe tire fixed- Ran over a large piece of metal while removing concrete at the park.

Beavers

- Ransom St Beavers- Checking on Beavers. 2 have been removed. Called the trapper back in because more have moved in from another property.

- Complaint about Beavers on Dolge Ave. 2 Beavers were spotted but haven't seen them sense.

Parks

- Park Bench Rehab is still in the works.
- Mowing is completed.
- Worked on Greenway Trail- Waiting on further word from the Trail people on the proposed repair. Only damaged decking has been pulled up.
- Winterized Gray Building at Center Park.
- Removed and mulched leaves from all parks.
- Pulled tables out of Plowe Park.
- Installed the Yearly Christmas Tree at Plowe Park.
- Cleaned Debris at Center Park Pavilion.
- Removed Concrete from Center Park Pavilion.

- Dug and confirmed the existence of a waiting pool in Center Park near Pavilion

To Do:

- Update Water Books
- Continue to train new employees
- Keep trucks serviced and cleaned.
- Cleaning and Organizing Garage
- “09” Freightliner- Rust Control.
- Removal of sediment at Reservoir to create room for next year.
- Burt St- Remove Vegetation